


Technical Data Sheet

Silduct 1S

Wall: One ply silicone coated glass -fibre fabric, single outer glass cord
Spiral: spring steel wire

For Medium and High Temperature use in welding, plastics, smoke, vapour or ventilation environments.

Hose & Ducting



Certificate Number: 14362
ISO 9001



Care should be taken in selecting the most suitable quality for each application. Advice is available, but final responsibility remains with the customer.

Web: www.epdm.co.uk

E-Mail: Sales@epdm.co.uk

Contact

Telephone: +44 (0)1625 573971

FAX: +44 (0)1625 573250

Munsch & Co/PTM Ltd

Units AG2/3 Clarence Mill
Clarence Road, Bollington

Macclesfield, Cheshire
SK10 5JZ

United Kingdom

Hose & Ducting

Part number	Inside Ø mm	WP bar	Vacuum m H ² O	Bending R. mm	Weight kg/m	Length m
P401019	19	1.5	5.3	9	0.08	4
P401022	22	1.5	5.3	11	0.08	4
P401025	25	1.4	5.3	12	0.12	4
P401032	32	1.4	5	16	0.13	4
P401038	38	1.4	5	19	0.16	4
P401041	41	1.3	4.5	21	0.17	4
P401044	44	1.2	4.4	22	0.19	4
P401051	51	1.2	4.4	25	0.25	4
P401057	57	1.1	4	28	0.28	4
P401063	63	1.1	4	31	0.3	4
P401070	70	1.1	3.5	35	0.39	4
P401076	76	1	3.5	38	0.41	4
P401083	83	1	3	41	0.47	4
P401089	89	0.9	2.95	44	0.49	4
P401095	95	0.9	2.7	47	0.54	4
P401102	102	0.9	2.6	51	0.57	4
P401108	108	0.8	2.3	54	0.68	4
P401114	114	0.8	2.1	57	0.73	4
P401121	121	0.8	1.9	60	0.76	4
P401127	127	0.8	1.7	63	0.8	4
P401140	140	0.8	1.5	70	0.88	4
P401152	152	0.6	1.4	76	1.05	4
P401160	160	0.6	1.2	80	1.09	4
P401178	178	0.6	1	89	1.21	4
P401203	203	0.5	0.7	101	1.38	4
P401229	229	0.4	0.6	114	1.49	4
P401254	254	0.4	0.5	127	1.65	4
P401305	305	0.1	0.3	152	2	4



Certificate Number: 14362
 ISO 9001



Care should be taken in selecting the most suitable quality for each application. Advice is available, but final responsibility remains with the customer.

Web: www.epdm.co.uk

E-Mail: Sales@epdm.co.uk

Contact

Telephone: +44 (0)1625 573971

FAX: +44 (0)1625 573250

Munsch & Co/PTM Ltd

Units AG2/3 Clarence Mill

Clarence Road, Bollington

Macclesfield, Cheshire

SK10 5JZ

United Kingdom